

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**


No. 179

Date: 17/07/2025

It is certified that an inspection team headed by Er. Imteyaz, Junior Engineer, Block – Manigachhi & Dharmendra Kumar, Chemist from PUBLIC HEALTH ENGINEERING DEPARTMENT inspected the SANSKRITI INTERNATIONAL SCHOOL, RAGHOPUR, MANIGACHHI, DARBHANGA dated on 15.07.2025 and found that the SANSKRITI INTERNATIONAL SCHOOL, RAGHOPUR, MANIGACHHI, DARBHANGA has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of 1 year.

Signature with Seal

  
17/07/2025  
Sub Divisional Officer

Name : Shiv Kumar

PH Sub Division, Darbhanga

Designation: Sub Divisional Officer

Name & Address of Office / Department: PH Sub Division

## District Level water Testing Laboratory Darbhanga DLWTL

Government of Bihar  
Public Health Engineering Department

District Name: Darbhanga  
Sample code - DBG/W/2025-2026/158

Sample collected by: Ravishankar Prasad  
Sample Collected On-15/07/2025

Sl. No.	Block	Panchayat	Village	Location of Source	Parameters															Remarks
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO3	SO4	F	As	Total Coil	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	20
1	Mangachhi	Taruni	Raghopur	Sanskrit International School	7.96	NT	686	446	210	56	16.8	86	232	NT	NT	NT	NT	NT	NT	
Desirable limit					6.5	5.0	500	200	75	30	250	200	0.3	45	25	1.0	0.01			
Permissible limit					8.5	10.0	2000	600	200	100	1000	600	1.0	NR	400	1.5	NR	**		

BDL- Below Deduction Limit  
NT- Not Test

  
 Chemist  
 P.H Division Darbhanga  
 P.H Division Darbhanga